



## FTAM.E158795 Gas and Vapor Detectors and Sensors

[Page Bottom](#)

---

### Gas and Vapor Detectors and Sensors

[See General Information for Gas and Vapor Detectors and Sensors](#)

#### MINE SAFETY APPLIANCES CO

E158795

1000 CRANBERRY WOODS DR  
CRANBERRY TOWNSHIP, PA 16066 USA

**Refrigerant monitor**, Model A-RT followed by A, B, C, D, F, H, I, L, N, O or R, followed by 1, 4 or 8, followed by 1, followed by 1, followed by 0 or S, followed by 0 or F, followed by 0 thru 8, followed by 0, followed by D, followed by 0, followed by 0, followed by 0, A, B, C, D, F, H, I, L, N, O, followed by 0, A, B, C, D, F, H, I, L, N, O, followed by 0, A, B, C, D, F, H, I, L, N, O, followed by 0, A, B, C, D, F, H, I, L, N, O, followed by 0, A, B, C, D, F, H, I, L, N, O, followed by 0, A, B, C, D, F, H, I, L, N, O, followed by 0, A, B, C, D, F, H, I, L, N, O. All model designations may be identified in the Series designation of Chillgard RT. Operating temperature 0-50 degrees C. Sensitivity range 0-50 plus or minus 1 ppm, 51-1000 ppm plus or minus 10 percent of reading (PPM-Parts Per Million). This product sensitivity range has been tested to accurately detect the following gases at its calibrated temperatures: CFC-11, CFC-12, CFC-22, CFC-113, CFC-114, CFC-500, CFC-502, HCFC-123, HFC-134a, HFC-404A.

[Last Updated](#) on 2009-12-17

---

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2010 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2010 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

